

Diversifying Heat Sources in China's Urban District Heating Systems Will Reduce Risk of Carbon Lock-in

Shangwei Liu¹, Yang Guo¹, Fabian Wagner², Hongxun Liu³, Ryna Yiyun Cui⁴, Denise L. Mauzerall^{1,5*}

¹ Princeton School of Public and International Affairs, Princeton University, Princeton, NJ, USA

² Energy, Climate and Environment Program, International Institute for Applied Systems Analysis (IIASA), Laxenburg, Austria

³ School of Economics and Finance, Xi'an Jiaotong University, Shaanxi, China

⁴ Center for Global Sustainability, School of Public Policy, University of Maryland, College Park, MD, USA

⁵ Department of Civil and Environmental Engineering, Princeton University, Princeton, NJ, USA

* Correspondence: mauzerall@princeton.edu

Abstract

China's clean heating policy since 2017 has notably improved air quality. However, the share of non-fossil sources in China's urban district heating systems remains low, and many new coal-fired combined heat and power (CHP) plants are being built. Strategic choices for district heating technologies are necessary for China to reach peak carbon emissions by 2030 and achieve carbon neutrality by 2060. Here we find that replacing polluting coal technologies with new and improved coal-fired CHP plants will lead to significant carbon lock-in and hinder decommissioning of associated coal-fired electricity generation. Expanding the use of industrial waste heat and air/ground-source heat pumps can avoid the need for new CHP construction and reduce carbon emissions by 27% from 2020 to 2030. Such a transition will unevenly increase heating costs depending on nearby availability of CHP and waste heat resources. Our findings inform implementation of the government's recent proposals to decarbonize district heating.

30 **Introduction**

31 Mitigating carbon emissions from heating buildings is a critical part of the global energy
32 transition¹. District heating systems, widely used in China, Russia, and Europe, distribute heat
33 from a central location through insulated pipes to buildings throughout a city. District heating is
34 promising for decarbonizing heating as it can integrate diverse low-carbon heat sources².
35 However, the full potential of district heating's decarbonization remains largely untapped. In
36 2020, fossil fuels accounted for 90% of global district heat production, contributing to nearly 4%
37 of global CO₂ emissions³. Meeting global climate goals requires a substantial increase in the use
38 of non-fossil energy sources, including industrial waste heat and large heat pumps powered by
39 decarbonized electricity, in district networks³.

40
41 Northern China hosts the world's largest district heating systems, consuming more energy than
42 the entire UK and contributing ~1.5% of global CO₂ emissions⁴. Until 2016, China's district
43 heating predominantly relied on inefficient polluting coal boilers and small-scale combined heat
44 and power (CHP) plants. In addition to carbon emissions, these facilities contributed to severe air
45 pollution, adversely affecting public health⁵. In response to the severe air pollution, the Chinese
46 government launched a nationwide clean heating campaign in 2017⁶. A primary objective of the
47 campaign was to replace polluting coal boilers and small-scale CHP plants with various clean
48 district heating technologies, including large and efficient CHP plants (equipped with air
49 pollutant emission control systems), natural gas boilers, and various non-fossil heating
50 technologies. As a result, urban district heating demand met by large CHP plants increased to
51 54% in 2021, greatly contributing to the notable improvements in air quality observed in China
52 in recent years^{7,8}. However, the share of non-fossil sources in China's district heating systems
53 remains low (~10% in 2021)⁸, falling short of the 27% non-fossil heating goals set by the clean
54 heating campaign for 2021⁹.

55
56 For China to peak carbon emissions by 2030, reducing emissions from district heating will be
57 crucial particularly in industrial cities where carbon emissions continue to rise¹⁰. Spurred by the
58 announcement of the 2060 carbon neutrality goal, the Chinese government recently announced
59 several clean heating policy proposals aimed at decarbonizing district heat, including increasing
60 heat electrification and deploying low-carbon district heating technologies (Supplemental Table
61 1). Meeting the carbon neutrality goal will require an extraordinary near-term effort to expand
62 low-carbon heat sources in China's district heating networks so that non-CHP sources contribute
63 nearly two-thirds of total district heating by 2030¹¹. Some studies highlighted the benefits of
64 increasing the use of coal-fired CHP resources but did not consider associated carbon lock-in
65 risks^{12,13}. No previous studies, to the best of our knowledge, have systematically evaluated the cost
66 and emission implications of district heating options in China (Supplementary Note 1).

67
68 Here we examine the cost and emission implications of various possible near-term (2020-2030)
69 district heating investment scenarios based on the assessment of 15 currently available district
70 heating technologies. These investment scenarios range from a business-as-usual scenario
71 ("high-coal"), representing practices prior to the carbon neutrality announcement, to an

72 ambitious decarbonization scenario (“low-coal”), consistent with the full implementation of
73 recent clean heating policy proposals. We find that the business-as-usual approach, i.e., replacing
74 polluting coal technologies with existing and new coal-fired CHP plants, while resulting in cost
75 savings, poses a risk of carbon lock-in and hinders the decarbonization of the power sector. In
76 contrast, we find that expanding the adoption of industrial waste heat and air/ground-source heat
77 pumps can facilitate achievement of the new heating policy proposals and avoid the need for new
78 CHP plant construction, leading to a 27% emission reduction from 2020 to 2030. Such transition
79 will increase the national total annualized costs per unit heat by 9% from 2020 to 2030, while
80 unevenly affecting cities depending on the nearby availability of CHP heating sources and
81 industrial waste heat.

82

83 **District heating technologies**

84 We assess CO₂ emissions, costs, and availability of various district heating technologies,
85 including five fossil fuel technologies and ten non-fossil technologies (Figure 1 and
86 Supplemental Table 2). Currently widely used coal-based technologies, i.e., coal boilers and
87 CHP-extraction, have low costs but high CO₂ emissions. Improved coal-fired CHP technology
88 utilizes large absorption heat pumps to recover waste heat from the power plants’ cooling system
89 (Supplementary Note 2), resulting in substantial reductions in both costs and emissions
90 compared to current coal-based technologies. We find that the improved CHP technology has
91 CO₂ emission factors only slightly higher than those of natural gas boilers and most grid-based
92 options that use the 2020 power mix.

93

94 Replacing coal-based technologies with non-fossil alternatives faces challenges due to limited
95 resources and higher costs. Most alternatives to coal-fired CHP, including those using heat
96 recovery from nuclear or chemical plants, municipal solid waste, biomass, or wastewater, have
97 limited resource availability. These technologies collectively can only meet a small fraction
98 (<10%) of the total district heating demand. Among the options suitable for large-scale
99 implementation, recovering waste heat from steel plants using large grid-based electric heat
100 pumps shows the greatest promise. This technology has costs comparable to current coal-based
101 technologies with significantly lower emissions as of 2020. Further emission reductions are
102 possible with grid decarbonization. Air/ground-source heat pumps are also widely applicable and
103 have operating costs similar to coal boilers; however, their capital costs are high. Hence, trade-
104 offs exist among various district heating options.

105

106 **Chinese district heating systems in 2030**

107 To represent various levels of penetration of non-fossil heating technologies combined with
108 existing and new CHP deployment in 2030, we develop three district heating investment
109 scenarios, including high-coal, mid-coal, and low-coal (Table 1). All three scenarios aim to
110 replace polluting coal boilers and small coal CHP plants with other options that satisfy the ~30%
111 increased district heating demand expected in 2030 relative to 2020^{11,14}. All three scenarios
112 assume the optimal use of existing CHP resources from existing coal-fired power plants as

113 proposed by existing policies (Supplemental Table 1).

114
115 New heat sources are necessary to meet 2030 heating demand. The high-coal scenario represents
116 the business-as-usual approach used prior to the carbon neutrality announcement and involves
117 the construction of many new coal CHP plants. The mid-coal scenario combines new coal
118 construction with adoption of cost-effective recovery of industrial waste heat from steel plants,
119 chemical plants and nuclear power plants. In contrast, the low-coal scenario represents a highly
120 ambitious near-term action consistent with the full implementation of recent clean heating policy
121 proposals. This scenario prohibits new coal CHP plant construction and reduces the capacity
122 factors of existing coal-fired power plants to align with the 2°C climate goal (Methods). The
123 low-coal scenario therefore necessitates the extensive integration of industrial waste heat and the
124 implementation of air/ground-source heat pumps.

125
126 Total carbon emissions from district heating will increase by 10% in the high-coal scenario but
127 will decrease by 3% and 27% in the mid-coal and low-coal scenarios in 2030, respectively,
128 compared to 2020 levels (Figure 2b). Notably, the low-coal scenario reduces carbon emissions
129 per unit heat by a third between 2020 and 2030. This reduction results from the widespread
130 deployment of low-carbon electric technologies and accelerated decarbonization of the power
131 grid.

132
133 Total heating costs per unit heat will decrease from 2020 to 2030 in the high-coal and mid-coal
134 scenarios because of the replacement of inefficient coal boilers with CHP plants, while heating
135 costs will rise in the low coal scenario, mainly due to the significant capital and operating costs
136 of electric heat pumps. For the low-coal scenario, we estimate that a total capital investment of
137 about 1 trillion yuan (~\$140 billion) between 2020 to 2030 is required to enable the
138 implementation of low-carbon district heating technologies. To provide context, in 2022 alone,
139 China invested nearly 4 trillion yuan (~\$546 billion) on clean energy including solar, wind,
140 electric vehicles, and batteries¹⁵. In addition, we find that in the low-coal scenario operating costs
141 per unit heat will increase by 12% in 2030 in the compared to 2020 levels (Figure 2d). In
142 Chinese district heating markets, operating costs are annually paid by households, while a
143 significant portion of upfront capital costs are covered by fees and taxes associated with home
144 purchases as well as government subsidies¹⁶. Thus, the increase in household annual heating
145 costs in the low-coal scenario are likely to be manageable, considering that household incomes
146 are projected to rise from 2020 to 2030 in China¹¹.

147
148 The abatement costs of CO₂ emissions in 2030 between the high-coal to low-coal scenarios will
149 be ~500 yuan per ton CO₂, and from the mid-coal to low-coal scenarios will be ~600 yuan per
150 ton CO₂. These abatement costs are lower than the social cost of carbon (i.e., the economic
151 damages that would result from one additional ton of CO₂ emissions) currently estimated at
152 ~1200 yuan per ton CO₂¹⁷. Carbon prices in China's carbon emissions trading markets were ~
153 70 yuan per ton CO₂ in 2023 and are projected to increase to 150-300 yuan per ton CO₂ by
154 2030¹⁸. The current and projected 2030 carbon prices are thus still insufficient to achieve the full

155 implementation of recent clean heating policy proposals.

156

157 **Carbon lock-in risks with new coal CHP investments**

158 The district heating investment approach used prior to the 2060 carbon neutrality goal
159 announcement, as represented by our high-coal scenario, involves the construction of many new
160 coal CHP plants. This approach, while leading to cost savings compared to a low-coal scenario,
161 will result in an increase in total carbon emissions from 2020 to 2030 in most northern Chinese
162 cities, making the achievement of China's 2030 carbon emissions peak target challenging.

163 Moreover, new and improved CHP plants require substantial investments and are built to last for
164 decades. Consequently, these plants may lock in a reliance on coal and continue to generate
165 emissions for decades, hindering the transition to alternative, low-carbon heating technologies
166 and the achievement of China's 2060 carbon neutrality target.

167

168 In addition, CHP plants generate heat and electricity simultaneously. Utilizing CHP plants for
169 residential district heating requires that these plants continue to operate to provide heat even if
170 the electricity can be obtained from non-fossil sources. This creates challenges for integrating
171 variable renewable energy into the power grid and minimizing renewable energy curtailment.
172 We find that in 2020, existing CHP plants lock in ~440 TWh of coal-fired electricity generation
173 during the heating season. This is equivalent to ~10% of Chinese coal power generation or ~5%
174 of global coal power generation.

175

176 If the new clean heating proposals are not implemented, coal CHP capacity will expand and
177 operate in accordance with our high-coal scenario. As a result, existing and new CHP power
178 plants will cumulatively lock in ~19,000 TWh coal-fired electricity and produce nearly 30 Gt
179 emissions from 2020 to 2060, assuming historical operational parameters (i.e., CHP plant
180 lifetime = 30 years, heat-to-power ratio = 1.5) (Figure 3). For comparison, GCAM-China, a
181 widely used integrated assessment model, determines that from 2020 onward the maximum
182 allowable Chinese coal-fired electricity generation that is compatible with the 1.5° and the well-
183 below 2°C targets are ~37,000 and ~63,000 TWh, respectively. Therefore, in the high-coal
184 scenario, the locked-in coal-fired electricity generation from CHP plants during the heating
185 season alone could represent ~50% of the 1.5°C budget and ~30% of the 2°C budget
186 (Supplemental Figure 1).

187

188 Under the high-coal scenario, adopting improved CHP technologies with higher district heat
189 production efficiency and a higher heat-to-power ratio offers a reduction of 4.5 Gt CO₂
190 emissions. Early retirement of CHP plants, for example, shortening the operational lifespan to 20
191 years, achieves another 4 Gt CO₂ emission reduction. However, early retirement may encounter
192 significant challenges. The low operating costs of CHP plants makes it difficult to replace them
193 with non-fossil technologies. Early retirement leads to stranded assets and drives up levelized
194 costs of heat, possibly leaving coal-asset owners unable to recover their initial investments
195 (Supplemental Figure 2).

196

197 The most effective way to reduce carbon lock-in is to avoid building new CHP plants and utilize
198 non-fossil alternatives. Committed CO₂ emissions drop to 17-23 Gt in the mid-coal scenario and
199 only 10 Gt in the low-coal scenario. The reduction of locked-in coal-fired electricity generation
200 also facilitates more integration of variable renewable energy, supporting the decarbonization of
201 electric district heating technologies.

202
203 Since 2020, local governments in China have approved a significant number of new coal power
204 plants including both CHP and electricity-only power plants (Supplemental Figure 3). We
205 examine the progress of new coal power projects across northern China using data from the
206 Global Coal Plant Tracker database¹⁹ and identify those that are or will be (partially) constructed
207 to meet the demand for residential district heating. We estimate that a total of ~74 GW of new
208 coal CHP projects, motivated by residential heating demand, are either constructed, under
209 construction, permitted or announced between Jan 2020 and June 2023. Many of these new
210 projects still intend to utilize the currently widespread CHP technology instead of adopting
211 improved technology which utilizes heat pumps to increase the efficiency of district heat
212 production.

213
214 We compare these new coal CHP pipeline plants with the necessary new coal CHP capacity in
215 2030 in our high-, mid-, and low-coal scenarios (Figure 4). We estimate that 140-250 GW, 90-
216 160 GW, and 0 additional GW of new coal CHP capacity is required to meet heating demand in
217 the high-, mid-, and low-coal scenarios, respectively. The range of estimates reflects variations in
218 assumptions regarding the capacity factors and heat-to-power ratios of new CHP plants
219 (Methods). Notably, new coal CHP capacity in the pipeline in provinces including Shanxi, Inner
220 Mongolia, and Ningxia already surpasses the projected necessary residential district heating
221 needs for 2030. Our results suggest that some of these new CHP plants can be replaced by
222 improving the use of CHP resources from existing coal-fired power plants. For newly
223 commissioned CHP plants, adopting the improved CHP technology and planning for early
224 retirement (or carbon capture retrofit) will be important to minimize future emissions.

225

226 **Strategies for a low-carbon district heating transition**

227 Diversifying heat sources in China's urban district heating systems by 2030 is critical to secure
228 the climate goals. Based on our findings from the low-coal scenario, we outline a city-level
229 strategy to avoid new coal CHP construction and meet the rising demand for district heating
230 between 2020 and 2030. This strategy represents the preferred option to fully implement the
231 recent clean heating policy proposals to promote the use of non-fossil technologies in district
232 heating. The strategy varies across cities primarily based on the availability of existing coal CHP
233 resources and industrial waste heat. Therefore, we categorize the ~300 cities into three main
234 groups according to their greatest heating resource availability: "Abundant CHP", "Abundant
235 Industrial Waste Heat" and "Limited Heating Resources" (Figure 5a).

236

237 More than half of the cities fall under the "Abundant CHP" group. For these cities, improving the
238 use of existing CHP resources to replace polluting coal technologies enables a gradual shift to

239 lower-carbon technologies. We find that existing CHP plants and existing pipelines can only
240 meet ~26% of the national urban district heat demand in 2030 due to retirements of existing CHP
241 plants and a reduction in capacity factors between 2020 and 2030 to facilitate power sector
242 decarbonization (Methods). However, with improvement measures, existing power plant
243 resources can meet ~41% of the urban district heating demand in 2030. These improvement
244 measures include converting existing electricity-only power plants into CHP plants (~50 power
245 plants), installing large absorption heat pumps to enhance district heat production efficiency
246 (~110 power plants), and constructing new heat transport pipelines (~110 new city-plant
247 pipelines) (Figure 5b). These new pipelines are longer, typically ranging from 15-70 km,
248 compared to most existing plant-city pipelines (<20 km). Total CO₂ emissions, total and
249 operating costs per unit heat in most “Abundant CHP” cities will remain similar to 2020 levels in
250 2030, despite an average 30% increase in district heating demand.

251
252 The “Abundant Industrial Waste Heat” group of cities presents a promising opportunity for a
253 swift transition to low-carbon heating technologies by 2030. These cities are predominantly
254 located in industry-heavy provinces, including Shandong, Liaoning and Jilin. Maximizing the
255 economic use of industrial waste heat requires retrofitting ~50 steel plants, two nuclear power
256 plants, a few chemical plants, and constructing ~55 associated new plant-city pipelines (Figure
257 5b). We estimate that integrating industrial waste heat into district heating will lead to a
258 substantial >50% reduction in CO₂ emissions relative to 2020 levels in most cities, greatly
259 helping these industrial cities in meeting the 2030 CO₂ emissions peak target. Moreover, total
260 costs per unit heat in most cities will remain similar to 2020 levels in 2030, while operating costs
261 will increase by an average of ~20% (Supplemental Figure 4).

262
263 The “Limited Heating Resources” group, with limited access to CHP resources and industrial
264 waste heat, faces challenges in adopting low-carbon technologies by 2030. If new coal CHP
265 construction is prohibited, extensive deployment of air/ground-source heat pumps is necessary
266 by 2030 to meet heating demand. This deployment will significantly cut CO₂ emissions by on
267 average 65% compared to 2020 levels (Supplemental Figure 4). However, it will also
268 significantly raise both total and operating costs per unit heat by more than half. This cost
269 increase is a significant challenge because these cities are largely located in economically
270 disadvantaged regions with high existing household heating burdens (due to cold climates and
271 low incomes), particularly in Heilongjiang, Jilin and Liaoning provinces^{5,11}. These results
272 highlight that targeted subsidies are needed to facilitate the low-carbon heating transition in these
273 cities.

274
275 Another option, which we find to be a less favorable choice compared to heat pumps, is to
276 expand the use of natural gas boilers and natural gas CHP plants as a bridge fuel to displace coal.
277 We estimate that, compared with deploying air/ground-source heat pumps, using efficient natural
278 gas technologies leads to slightly smaller emissions reductions with slightly lower total costs and
279 higher operating costs in 2030 (Supplemental Figure 5). Such expansion of natural gas heating
280 will require more than doubling the district heating sector’s natural gas consumption from 2020

281 to 2030, potentially increasing the risk of energy insecurity due to China’s heavy reliance on
282 imported natural gas²⁰. Moreover, natural gas CHP plants will also lock in CO₂ emissions from
283 both district heat production and electricity production, similar to coal CHP that we have
284 discussed. Our emission calculations do not include natural gas leakages. Previous studies show
285 that natural gas may even have a similar carbon intensity to coal with a high leakage rate²¹.
286 These results indicate that the adoption of air/ground-source heat pumps to replace coal
287 technologies, instead of natural gas, on a large scale should be preferred.
288

289 **Discussion**

290 Our findings highlight the substantial impact of near-term investments in district heating systems
291 on China’s decarbonization trajectory. The high-coal approach used prior to the carbon neutrality
292 target announcement continues to result in the construction of new CHP plants, leading to carbon
293 lock-in and hindering the decarbonization of the power sector. The Chinese government recently
294 announced several proposes to decarbonize the district heating sector (Supplemental Table 1),
295 which is critical for China to secure its climate goals. Our findings inform implementation of
296 these clean heating policy proposals.
297

298 We also highlight a crucial but often overlooked challenge in reducing coal power generation:
299 the reliance on coal-fired CHP facilities for district heating. While previous studies have
300 explored ways to decrease coal power generation by ramping up renewables and storage^{22,23}, few
301 have addressed the decarbonization of CHP systems in the context of simultaneously meeting
302 both heat and power demands. This is particularly important because relying on coal-fired CHP
303 for district heating hinders decommissioning associated electricity generation.
304

305 Instead of using CHP, an alternative is to deploy low-carbon heating technologies, particularly
306 recovering industrial waste heat and using air/ground-source heat pumps while decarbonizing the
307 power grid. In our low-coal scenario, electric technologies, including waste heat recovery with
308 large electric heat pumps and air/ground-source heat pumps, will meet 34% of total district
309 heating demand in 2030. This substantial electrification necessitates a significant expansion of
310 clean power infrastructure, requiring an additional ~200 TWh of electricity generation during the
311 heating season (Supplemental Figure 6). To provide context, China is on track to build an
312 additional 700 GW of utility-scale wind and solar capacity by 2030^{24,25} and we estimate that
313 these new sources will generate ~500 TWh of electricity during the heating season. The
314 associated operational challenges of renewable grid integration are not fully captured by our
315 annual supply-demand matching approach^{1,26}. However, such limitations will not impact our
316 main conclusions as renewable integration only has marginal effects on power grid costs by
317 2030²⁷⁻²⁹.
318

319 Our analysis primarily focuses on the impacts of near-term (2020-2030) investments in district
320 heating systems due to their direct and immediate policy implications. However, the path to
321 achieving carbon neutrality in China’s district heating systems by 2060 remains unclear. An
322 important uncertainty pertains to the future availability of waste heat sources for district heating

323 systems. For example, the availability of waste heat may decrease if a steel plant decarbonizes by
324 shifting from a blast furnace to an electric arc furnace. Conversely, waste heat from data centers
325 is expected to rise due to the growing demand for computing resources³⁰. Another important
326 challenge is to ensure power grid reliability with high district heat electrification, which leads to
327 a substantial increase in winter electricity demand²⁶. Promising solutions include long-duration
328 energy storage^{31,32}, dual-fuel systems¹, and demand-side flexibility³³, but detailed assessments
329 are needed. Previous studies have also suggested deploying CHP systems with carbon capture
330 and storage on a large scale to decarbonize district heating^{14,34}. However, the feasibility, costs,
331 environmental implications, and impact on power grid flexibility need to be carefully examined.
332

333 While this study primarily addresses the supply-side transition to low-carbon options, improving
334 demand-side energy efficiency is also very important. Substantial potential for energy efficiency
335 improvements exists across northern China. Currently, ~20% of district heat production is lost
336 due to overheating and network losses, and about 40% of urban residential buildings lack
337 adequate insulation⁴. Improving energy efficiency can lower energy consumption and peak
338 loads, reducing the need for extensive infrastructure upgrades and associated costs and
339 emissions²⁶. Moreover, improving energy efficiency enables more efficient use of electric heat
340 pumps for district heating by lowering required water temperatures in heating networks³⁵.

341
342 Our analysis only includes technical and engineering costs and does not account for the “soft
343 costs” associated with political and social challenges³⁶. Soft costs are often higher for emerging
344 low-carbon technologies, as they lack an established market presence⁴. Government policies are
345 necessary to enable the adoption of low-carbon alternatives to displace coal-fired CHP
346 technologies. This could involve implementing mandates such as renewable heating portfolio
347 standards or mandatory building codes, as well as offering subsidies to low-carbon technologies
348 and establishing government procurement policies.

349 **Methods**

350 **Infrastructure database**

351 We compile an infrastructure database of China’s coal-fired power plants, steel plants, chemical
352 plants, nuclear power plants and urban district heating systems, utilizing data sources including
353 Global Coal Plant Tracker (Jun 2023)¹⁹, Global Steel Plant Tracker (March 2022)³⁷, recent peer-
354 reviewed literature³⁸, industry reports, and Chinese Urban Infrastructure Statistical Yearbooks³⁹.
355 We do not consider the utilization of waste heat from cement plants because most of China’s
356 cement plants cease production during the heating season. This regulatory measure is
357 implemented to mitigate air pollution in winter and tackle overcapacity issue in the cement
358 sector. For coal-fired power plants, we use publicly accessible project information and company
359 homepages of power plants to identify whether a power plant is CHP plant and, if so, which
360 cities it is or will be supplying district heat to. Our infrastructure database includes detailed
361 information including capacities, status, technologies, locations, vintage years for ~1000 coal-
362 fired power plants, ~170 steel plants, ~150 chemical plants, and 2 nuclear power plants
363 (“Hongyanhe” in Liaoning and “Haiyang” in Shandong) in northern China (Supplemental Figure
364 7).

366 This database also includes locations, district heating capacity, and district heating demand for
367 ~300 cities (including both city proper areas of prefecture-level cities and county-level cities) in
368 15 provinces in northern China, using data from 2020 Chinese Urban Infrastructure Statistical
369 Yearbooks. China’s district heating systems are predominantly located in the northern regions of
370 the country, where the climate is colder and heating demand is higher. We determine the specific
371 location of each city by first identifying the “urban grid cells” with a population density of >1000
372 persons/km² using a Chinese population gridded map⁴⁰. We use the center points of these “urban
373 grid cells” as the geographic coordinates (latitude and longitude) for each city. We estimate
374 urban district heating demand for each city in 2030 based on projected future population⁴⁰ and
375 per capita district heating demand¹⁴ (Supplementary Notes 3).

377 We also collect data on the amount of municipal solid waste (MSW) and wastewater treatment at
378 the city level in 2020 from Chinese Urban Infrastructure Statistical Yearbooks³⁹. We use the
379 biomass resource map developed by Wang et al. (2023)⁴¹ to calculate the potential for district
380 heating generation from burning agricultural and forestry residues (Supplementary Notes 3).

382 **Carbon emissions calculation**

383 We calculate carbon emissions using the specific emission factors for each district heating
384 technology. The CHP extraction and CHP absorption heat pump systems operate using coal-
385 produced hot steam, and their carbon intensity is determined by the steam’s emission factors and
386 heat production efficiency (Supplemental Figures 8-9 and Supplemental Table 3 for details). CO₂
387 emission factors of combustion heating technologies, including coal boilers, natural gas boilers,
388 MSW incineration, and biomass boilers are obtained from previous studies^{5,42} (Supplementary
389 Note 3 and Supplemental Tables 4-5). For grid-based electric technologies, we estimate the

390 carbon intensity of grid-based electricity in 2020 and 2030 using data from the IEA’s stated
391 policy and sustainable development scenarios, as well as proposed provincial renewable portfolio
392 goals⁴³ (Supplemental Table 6).
393

394 **District heat production potential calculation**

395 We estimate the plant-level district heat production potential (*DHPP*) for coal-fired power
396 plants, steel plants, chemical plants, nuclear power plants. For coal-fired power plants, the CHP
397 extraction technology and CHP absorption heat pump technology require extracting hot steam
398 from the turbine, and the amount of steam that can be extracted is limited by the amount of
399 electricity generated³². For these two technologies, we calculate the district heat production
400 potential based on unit capacity (*C*), capacity factors (*CF*), local heating days (*HD*), and
401 maximum heat-to-power ratios (*HtPR*) as outlined in equation (1) (Supplemental Table 7). Unit-
402 level maximum heat-to-power ratios are calculated based on unit capacity and cooling methods
403 (Supplemental Table 8)¹². The extraction-condensing method has a *HtPR* of 1.3-1.6, while the
404 absorption heat pump method has a higher *HtPR* of ~1.8 due to waste heat recovery. We also use
405 equation (1) to calculate district heat production potential for nuclear power plants. The
406 maximum heat-to-power of nuclear power plants is 1.6⁴⁴.

$$407 \quad DHPP = C \times CF \times \frac{HD}{365} \times HtPR \quad (1)$$

408 Electric compression heat pumps can also recover waste heat from coal-fired power plants, steel
409 plants, and chemical plants. For coal-fired power plants, we estimate the amount of recoverable
410 waste heat (*RWH*) in the condenser based on power generation and power cycle efficiency (η)
411 using equation (2). The percentage of total energy input contained in the condenser is
412 represented as α (Supplemental Table 9)⁶. For steel and chemical plants, we estimate the amount
413 of *RWH* based on plant-level production capacity, utilization factors, and waste heat generation
414 per industrial product (Supplemental Table 10). We then estimate district heat production
415 potential using the coefficient of performance (*COP*) of the large electric heat pump
416 technology⁴⁵, as outlined in equation (3).

$$417 \quad RWH = (C \times CF \times \frac{HD}{365}) \times \frac{1}{\eta} \times \alpha \quad (2)$$

$$418 \quad DHPP = RWH \times \frac{COP}{COP-1} \quad (3)$$

419 For local low-carbon heating resources (MSW, wastewater, and biomass), we estimate their city-
420 level district heat production potential based on the amount of MSW, urban wastewater, and
421 crop/forestry residues (Supplementary Note 3).
422

423 **Matching industrial plants with cities**

424 Heat produced in industrial plants (including coal-fired power plants, steel plants, chemical
425 plants, nuclear power plants) needs to be transported to cities through long-distance pipelines.
426 We first pair existing coal-fired CHP plants with cities that are already connected by existing
427 heat transport pipelines. We also propose possible construction of new heat transport pipelines
428 from industrial plants to cities. These proposals are based on an optimization algorithm for the

429 fixed charge transportation problem (FCTP)⁴⁶, as described in equations (4)-(6).

$$430 \quad z(F) = \min \sum_i \sum_j (pc \cdot d_{ij} y_{ij} + fc \cdot x_{ij} + tc \cdot d_{ij} x_{ij}) \quad (4)$$

$$431 \quad s.t. \sum_j x_{ij} \leq a_i, \sum_i x_{ij} - ld_{ij} y_{ij} = b_j, \sum_i x_{ij} - ld_{ij} y_{ij} \geq 0 \quad (5)$$

$$432 \quad x_{ij} \leq m_{ij} y_{ij}, \quad m_{ij} = \min\{a_i, b_j\}, \quad x_{ij} \geq 0, \quad y_{ij} \in \{0,1\}, \quad y_{ij} = 1 \text{ for existing linkages} \quad (6)$$

433 The objective of this FCTP is to minimize the annual total costs, including a fixed cost (pipeline
434 costs, $pc \cdot d_{ij} y_{ij}$) and two types of operating costs (fuel costs $fc \cdot x_{ij}$ and heat transport costs $tc \cdot$
435 $d_{ij} x_{ij}$). Each industrial plant has a district heat production potential a_i and each city requires a
436 certain quantity b_j of district heat from the industrial plants. x_{ij} and y_{ij} are decision variables in
437 the optimization problem. x_{ij} represents the quantity of district heat sent from industrial plant i to
438 city j . y_{ij} is a 0-1 variable that equals 1 if there is a heat transport pipeline from industrial plant i
439 to city j . y_{ij} is set to 1 for existing linkages. d_{ij} is the distance between industrial plant i and city
440 j , and l denotes the annual heat loss factor, in the unit of GJ/km. pc , fc and tc represent
441 annualized pipeline unit costs (in the unit of yuan/km), operating unit costs (yuan/GJ), and heat
442 transport unit costs (yuan/(km·GJ)), respectively.

443

444 In the case where district heating demand exceeds the supply from existing industrial facilities,
445 we add a dummy plant with high penalty fuel costs to balance the model. Cities receiving heat
446 from the dummy plant implies that their demand cannot be satisfied by existing industrial
447 facilities alone, and additional heating sources (e.g., new coal CHP, air/ground-source heat
448 pumps) are required.

449

450 We exclude the consideration of interprovincial heat transport pipelines (except the Beijing-
451 Tianjin-Hebei region) due to the significant political challenges involved, such as challenges in
452 acquiring land and obtaining permits and approvals. We treat the Beijing-Tianjin-Hebei region as
453 one province because currently coal-fired CHP plants in Hebei are used to meet district heating
454 demand in Tianjin and Beijing. We assume this practice will continue through 2030. We exclude
455 the proposed pipelines that exceed 150 km in length due to high construction cost and heat loss
456 during transport⁴⁷.

457

458 **District heat cost calculation**

459 We evaluate operating costs and annualized total costs per unit heat (annualized upfront capital
460 costs plus operating costs per unit heat) of various district heating technologies. The annualized
461 total costs per unit heat (ATC) of a district heating technology in year t can be calculated as
462 equation (7):

$$463 \quad ATC_t = \left(\frac{I}{AF} + OC_t\right)/H_t \quad (7)$$

464 where I denotes the initial investment costs (Supplemental Table 11) and AF denotes the annuity
465 factor. The discount rate is set at 7% in our analysis. OC_t denotes annual operating costs
466 (including fuel costs, operating and maintenance costs, and heat transport costs) in year t . H_t
467 represents the amount of heat delivered to the city (excluding heat loss if involving heat
468 transport) in year t . See details in Supplementary Note 3. Our estimates of emissions,

469 availability, costs of various district heating technologies are generally consistent with previous
470 literature^{11–13}(Supplementary Note 1).

471

472 **Power sector scenarios**

473 Most existing large coal power plants in China, particularly CHP plants, are expected to continue
474 operating at their current capacity factors during the heating season until the end of their
475 historical lifespan (~30 years) in a business-as-usual scenario. However, to meet well below 2°C
476 climate goals, a rapid reduction in coal use in power generation is necessary⁴⁸. Therefore, we
477 design two power sector decarbonization scenarios to represent possible power sector
478 decarbonization between 2020 and 2030: (1) a Business-As-Usual (BAU) scenario, which
479 assumes that coal power plants operate at their 2019 capacity factors until the end of their
480 historical lifespan of 30 years. We assume that the share of non-fossil sources in China’s total
481 power generation will increase from ~35% in 2020 to ~45% in 2030, according to China’s
482 proposed renewable portfolio standards, and (2) an Accelerated Power Sector Decarbonization
483 scenario, which represents an ambitious climate policy that the same power plants continue to
484 operate but their capacity factors are reduced by ~18% from 2020 to 2030 to align with the well-
485 below 2°C-consistent decarbonization pathway. This also aligns with current policies that require
486 coal-fired power plants to become more flexible to integrate renewable energy sources. We
487 assume that the share of non-fossil sources in China’s total power generation will increase to
488 ~67% in 2030 based on IEA’s estimates (Supplemental Table 6).

489

490 We determine the maximum allowable Chinese coal-fired electricity generation from 2020
491 onward that is compatible with the 1.5°C (modeled as a ~50% chance to reach the 1.5°C climate
492 goal) and well below 2°C targets (modeled as a ~66% chance to reach the 2°C climate goal),
493 using an integrated assessment model, GCAM-China (China-focused version of the Global
494 Change Analysis Model). The simulated well below 2°C-consistent mitigation pathways show
495 that China will achieve carbon neutrality by 2070 and that China’s unabated conventional coal
496 power generation will peak in 2020 and be phased out by 2055. While China’s pledge to peak
497 CO₂ emissions by 2030 and reach carbon neutrality by 2060 can be seen as compatible with the
498 2°C climate goal in the long run, its current coal power policies indicate that coal power
499 generation will not peak until 2030⁴⁹. Therefore, our 2°C-consistent coal power phasedown
500 scenarios represent a more ambitious near-term climate effort. The details of these power sector
501 decarbonization scenarios are described in a previous study⁵⁰.

502

503 **District heating investment scenarios**

504 We develop three district heating scenarios (high-coal, mid-coal, and low-coal) to represent
505 various possible near-term investment in China’s district heating systems between 2020 to 2030
506 (summarized in **Table 1**). These scenarios range from a business-as-usual scenario (high-coal),
507 reflecting practices prior to the carbon neutrality announcement, to an ambitious decarbonization
508 scenario (low-coal), consistent with the full implementation of recent clean heating policy
509 proposals. The mid-coal scenario represents a partial implementation of these proposals, utilizing

510 the most cost-effective industrial waste heat for district heating. We assume that existing
511 polluting coal boilers and smaller coal CHP plants (constructed before 2016) must be replaced by
512 2030 to tackle air pollution, aligning with national and regional environmental policies
513 (Supplemental Table 1).

514
515 We assume the proportion of natural gas boilers will remain similar from 2020 to 2030 as
516 existing natural gas infrastructure is expected to continue being utilized in 2030 and China's
517 natural gas consumption is likely to see a moderate increase in the near term. Utilizing natural
518 gas boilers for backup heating can help address grid challenges associated with increased
519 electrification in district heating¹.

520
521 New investments in district heating technologies are needed to replace polluting coal
522 technologies and meet the rising demand from 2020 to 2030. We begin with assuming that
523 20/50/80% of available local low-carbon heating resources (MSW, wastewater, biomass) will be
524 used in 2030 in the high/mid/low-coal scenarios. However, these resources can only cover a
525 small part (usually <10%) of heating needs in most cities.

526
527 We then explore using existing coal CHP resources and industrial waste heat to meet the
528 remaining demand. Industrial waste heat is not considered in the high-coal scenario. All three
529 scenarios assume the optimal use of existing CHP resources from existing coal-fired power
530 plants commissioned before 2020, as proposed by existing policies (Supplemental Table 1).
531 Using the optimization algorithm described above, we identify the most cost-effective linkages
532 between industrial plants (coal-fired power plants, steel plants, chemical plants, and nuclear
533 plants) and cities. Any linkages with total heating costs lower than air/ground-source heat pumps
534 are considered as "constructed" by 2030. For each coal-fired power plant-city linkage, we
535 calculate costs for three possible technologies (extraction, absorption heat pumps, waste heat
536 recovery using electric heat pumps) and select the lowest-cost option. Waste heat recovery using
537 electric heat pumps is more expensive than the other two technologies due to high electricity
538 prices.

539
540 For the remaining heating demand, new CHP plants are assumed to be constructed in the high-
541 and mid-coal scenarios, and air/ground-source heat pumps are deployed in the low-coal scenario.
542 In the latter case, the lowest-cost options from air- or ground-source heat pumps are chosen for
543 each province. Our analysis mainly considers the adoption of large, community-level air/ground-
544 source heat pumps to produce heat that would be circulated through an existing district heating
545 system.

546
547 To engage the ongoing debate in China regarding the potential benefits of expanding the use of
548 natural gas heating, we also design a supplementary low-coal-natural-gas-heating scenario. In
549 this scenario, everything remains the same as the low-coal scenario, except for the use of
550 efficient natural gas CHP plants (with absorption heat pumps to recover waste heat), instead of
551 air/ground-source heat pumps, to meet the remaining demand unmet by existing heating

552 resources. This scenario represents recent proposals to use natural gas as a bridge fuel to displace
553 coal in cities with limited low-carbon heating resources⁵¹.

554
555 In our high/mid-coal scenarios for district heating, where new coal CHP is allowed, we assume
556 that the power sector will decarbonize following the BAU power sector scenario. In the low-coal
557 scenario where new coal CHP is prohibited, we assume that the power sector will decarbonize
558 following the Accelerated Power Sector Decarbonization scenario.

559
560 The transition to low-carbon district heating will affect carbon emissions and costs differently
561 across regions, mainly due to the availability of existing coal CHP resources and industrial waste
562 heat. To illustrate this, we categorized ~300 cities with existing district heating systems based on
563 their greatest heating resource availability. Cities where existing district heating resources
564 (including existing coal CHP, industrial waste heat, MSW, wastewater, and biomass) cannot
565 meet >50% of the 2030 heating demand are in the “Limited Heating Resources” group. The
566 remaining cities are categorized by their main heating resource: “Abundant CHP”, and
567 “Abundant Industrial Waste Heat”. Smaller cities which have relatively modest heating demand
568 and can rely on local low-carbon heating sources such as MSW, wastewater, and biomass, are
569 grouped into the “Local Low-Carbon” category. Beijing primarily uses natural gas for heating.
570

571 **New coal CHP capacity**

572 We calculate the necessary new coal CHP capacity ($Cap_{newCHP,p}$) in province p from 2020 to
573 2030 in the high/mid/low-coal scenarios using equation (8):

$$574 \quad Cap_{newCHP,p} = \frac{H_{newCHP,p}}{HD_p \cdot 24 \cdot CF_{new} \cdot HtPR_{new}} \quad (8)$$

575 where $H_{newCHP,p}$ represents the heating demand that must be met by new coal CHP in 2030 in
576 the high/mid/low-coal scenarios. In the low-coal scenario, $H_{newCHP,p}$ is zero. HD_p is the number
577 of heating days in each province. CF_{new} denotes the capacity factor for new CHP plants, which
578 we assume to be 0.4-0.6 in our analysis¹¹. $HtPR_{new}$ is the heat-to-power ratio for new CHP
579 plants, which we assume to be between 1.5 (currently widely used extraction technology) and 1.8
580 (the state-of-the-art improved CHP technology) in our analysis⁵².

581

582 **CHP Carbon lock-in**

583 We estimate the locked-in coal-fired electricity generation associated with district heat
584 production from CHP plants, as well as the committed emissions from existing and new CHP
585 power plants from 2020 to 2060. This estimation is based on unit capacity factors, lifetime, heat-
586 to-power ratios, and the required district heating generation from new CHP plants. This
587 calculation focuses solely on emissions associated with district heat generation thus excluding
588 CHP plant emissions occurring during the non-heating season. See details in Supplementary
589 Note 3. We also estimate the impact of CHP plant lifetime, CHP technology choices and other
590 factors on the levelized costs of heat for the new CHP plant (Supplemental Figure 3).

591 **Data Availability**

592 Datasets of coal-fired coal power plants, steel plants, nuclear plants were obtained from the
593 Global Energy Monitor (<https://globalenergymonitor.org/>)¹⁹ and recent peer-reviewed
594 literature³⁸. Urban district heating data were retrieved from Chinese Urban Infrastructure
595 Statistical Yearbooks³⁹. All data generated and analyzed in this study are available within the
596 Supplementary Information and Supplementary Data files.

597

598 **Code Availability**

599 GCAM-China is an open-source model publicly available at [https://github.com/JGCRI/gcam-](https://github.com/JGCRI/gcam-core/releases)
600 [core/releases](https://github.com/JGCRI/gcam-core/releases) and a previous paper⁵⁰. The plant-city matching algorithm is conducted using PuLP
601 2.7.0, a linear programming model written in Python, available at <https://pypi.org/project/PuLP/>.

602

603 **Acknowledgments**

604 We thank the reviewers for their thoughtful comments which improved our manuscript. We
605 thank the Princeton School of Public and International Affairs at Princeton University for
606 supporting S.L. and the National Natural Science Foundation of China (No. 72273102) for
607 supporting H.L.

608

609 **Author Contributions Statement**

610 S.L. and D.L.M. conceived the idea for this project and designed the research. S.L. performed
611 the research. Y.G. and F. W, contributed to method design and analysis. Y.G., H.L., and R.C.
612 contributed data. S.L. and D.L.M. wrote the manuscript with feedback from all other authors.

613

614 **Competing Interests Statement**

615 The authors declare no competing interests.

616 **Tables**

617
618

Table 1. Scenario design for China’s district heating systems in 2030.

	High-coal scenario	Mid-coal scenario	Low-coal scenario
Coal boilers/small CHP	Phased out	Phased out	Phased out
Natural gas boilers	Same share as in 2020	Same share as in 2020	Same share as in 2020
Existing coal CHP resources	Optimal use of existing CHP resources	Optimal use of existing CHP resources	Optimal use of existing CHP resources
Coal power capacity factors	Continue to operate at 2019 capacity factors	Continue to operate at 2019 capacity factors	Reduced to meet the 2°C climate goal (avg ~18%)
Power sector decarbonization scenario	Business-As-Usual scenario	Business-As-Usual scenario	Accelerated Power Sector Decarbonization scenario
Local low carbon heating sources (MSW, biomass, wastewater)	20% of total potential	50% of total potential	80% of total potential
Industrial waste heat (steel, chemical, nuclear)	Not considered	Used if cheaper than air/ground-source heat pumps	Used if cheaper than air/ground-source heat pumps
Air/ground-source heat pumps	Not considered	Not considered	Used to meet remaining heating demand
New coal power plant construction	Allowed	Allowed	Not allowed
Resulting coal CHP share in 2030	~81%	~67%	~41%

619

620 **Figure Legends/Captions**

621 **Figure 1. Carbon emissions and costs for 15 district heating technologies. a-c**, carbon emissions per unit
622 heat (a) in 2020, (b) in 2030 under the Business-as-usual (BAU) electricity generation scenario (c) in 2030 under
623 the Accelerated Power Sector Decarbonization scenario. **d**, annualized total costs (annualized capital costs plus
624 operating costs) per unit heat in 2020. **e**, operating cost per unit heat in 2020.

625
626 For coal boilers (T1), natural gas boilers (T4), natural gas CHP with absorption heat pumps (T5), and biomass
627 boilers (T7), segments show the typical range of their costs and emissions, which vary mainly due to combustion
628 efficiency and fuel costs.

629
630 For technologies involving long-distance plant-city heat transport (T2, T3, T8, T9, T10, and T11), each point
631 represents a plant-city linkage, and box plots depict data distribution with central lines as medians, and boxes
632 for data quartiles. Emissions and costs vary mainly because of plant sizes, plants' remaining lifetimes, plant-
633 city distances, local grid carbon intensities, and local residential electricity prices.

634
635 For MSW incineration (T6), wastewater-source heat pumps (T12), air-source heat pumps (T13), ground-source
636 heat pumps (T14), and electric resistance boilers (T15), each point shows costs/emissions in a province, with
637 variations mainly due to different MSW composition, residential electricity prices, grid carbon intensities, and
638 heat pump efficiency among provinces.

639
640 **Abbreviations:** CHP, combined heat and power; MSW, municipal solid waste; WHR, waste heat recovery with
641 electric heat pumps.

642
643
644
645 **Figure 2. District heating generation, costs, and emissions, by sources, in 2020 and three scenarios**
646 **projected for 2030. a**, district heating generation. **b**, district heating CO₂ emissions. Average CO₂ emissions per
647 unit heat are shown in parentheses. **c**, district heating total costs (annualized capital costs plus operating costs).
648 Average heating total costs per unit heat are shown in parentheses. **d**, district heating operating costs. Average
649 operating costs per unit heat are shown in parentheses.

650 **Abbreviations:** CHP, combined heat and power; MSW, municipal solid waste; WHR, waste heat recovery with
651 electric heat pumps.

652
653
654
655 **Figure 3. Locked-in coal-fired electricity generation and committed CO₂ emissions from existing and new**
656 **combined heat and power (CHP) plants during the heating season in high/mid/low-coal scenarios from**
657 **2020 to 2060. a**, locked-in coal-fired electricity generation. **b**, committed CO₂ emissions.

658
659
660
661
662 **Figure 4. Required new coal combined heat and power (CHP) capacity in the low/mid/high coal scenarios**
663 **by 2030 (bars) and new coal CHP capacity in the pipeline (triangles) as of Jun 2023 in northern China.**
664 The range of required new coal estimates reflects variations in assumptions regarding seasonal power capacity
665 factors and heat-to-power ratios of new CHP plants (low value: capacity factor = 0.6, heat-to-power ratio = 1.8;
666 high value: capacity factor = 0.4, heat-to-power ratio = 1.5). No new coal CHP occurs under the low coal scenario.
667 We do not consider CHP projects that have been recently shelved, mothballed, or cancelled. We also do not
668 include those CHP plants used only for industrial heat. **BTH:** Beijing-Tianjin-Hebei region. We treat the BTH
669 region as one province because currently coal-fired CHP plants in Hebei are used to meet district heating demand
670 in Tianjin and Beijing. We assume this practice will continue through 2030.

671
672
673
674
675
676
677
678
679
680
681
682

Figure 5. Geographic map of city groups and required infrastructure investments in the low-coal scenario. a, Geographic map of city groups in northern China. Cities are categorized into three groups according to their greatest heating resource availability: “Abundant CHP” (172 cities, representing 62% of total district heating demands in northern China), “Abundant Industrial Waste Heat” (29 cities, 12% of total) and “Limited Heating Resources” (68 cities, 20% of total). Additionally, 28 smaller cities (1% of total) can rely on local low-carbon heating sources (MSW, wastewater, biomass) due to their relatively modest heating demand. Beijing relies on natural gas for heating demand. **b,** cities, industrial facilities (CHP power plants, steel plants, nuclear plants, and chemical plants), existing and new city-plant heat transport pipelines in 2030 in the low-coal scenario. **Abbreviations:** CHP, combined heat and power; MSW, municipal solid waste.

683 **References:**

- 684 1. Waite, M. & Modi, V. Electricity Load Implications of Space Heating Decarbonization
685 Pathways. *Joule* **4**, 376–394 (2020).
- 686 2. Werner, S. International review of district heating and cooling. *Energy* **137**, 617–631
687 (2017).
- 688 3. IEA. *Tracking Clean Energy Progress 2023*. [https://www.iea.org/reports/tracking-clean-](https://www.iea.org/reports/tracking-clean-energy-progress-2023)
689 [energy-progress-2023](https://www.iea.org/reports/tracking-clean-energy-progress-2023) (2023).
- 690 4. IEA. *District Energy Systems in China*. (2019).
- 691 5. Zhou, M. *et al.* Environmental benefits and household costs of clean heating options in
692 northern China. *Nat Sustain* (2021) doi:10.1038/s41893-021-00837-w.
- 693 6. NDRC (National Development and Reform Commission of China). Clean winter heating
694 planning for northern areas (2017–2021). [http://www.gov.cn/xinwen/2017-](http://www.gov.cn/xinwen/2017-12/20/content_5248855.htm)
695 [12/20/content_5248855.htm](http://www.gov.cn/xinwen/2017-12/20/content_5248855.htm) (2017).
- 696 7. Meng, W. *et al.* Differentiated-Rate Clean Heating Strategy with Superior Environmental
697 and Health Benefits in Northern China. *Environ Sci Technol* **54**, 13458–13466 (2020).
- 698 8. Nie, Y., Deng, M., Shan, M. & Yang, X. Clean and low-carbon heating in the building
699 sector of China: 10-Year development review and policy implications. *Energy Policy* **179**,
700 113659 (2023).
- 701 9. China Energy News. Renewable Energy Heating Market Feels Chilled. (2020).
- 702 10. Shan, Y. *et al.* City-level emission peak and drivers in China. *Sci Bull (Beijing)* **67**, 1910–
703 1920 (2022).
- 704 11. Wang, Z. *et al.* Unequal residential heating burden caused by combined heat and power
705 phase-out under climate goals. *Nat Energy* (2023) doi:10.1038/s41560-023-01308-6.
- 706 12. Zheng, W., Zhang, Y., Xia, J. & Jiang, Y. Cleaner heating in Northern China: potentials
707 and regional balances. *Resour Conserv Recycl* **160**, 104897 (2020).
- 708 13. Ramaswami, A. *et al.* Urban cross-sector actions for carbon mitigation with local health
709 co-benefits in China. *Nat Clim Chang* **7**, 736–742 (2017).
- 710 14. Guo, S., Jiang, Y. & Hu, S. The Pathways toward Carbon Peak and Carbon Neutrality in
711 China’s Building Sector. *Chinese Journal of Urban and Environmental Studies* **10**,
712 (2022).
- 713 15. BloombergNEF. *Energy Transition Investment Trends 2023*. (2023).
- 714 16. National Energy Administration. Drafting Guidelines for Opinions on Promoting
715 Renewable Energy Heating. (2017).
- 716 17. Rennert, K. *et al.* Comprehensive evidence implies a higher social cost of CO₂. *Nature*
717 **610**, 687–692 (2022).
- 718 18. Refinitiv. China’s national carbon market exceeds expectations.
719 [https://www.refinitiv.com/perspectives/future-of-investing-trading/chinas-national-](https://www.refinitiv.com/perspectives/future-of-investing-trading/chinas-national-carbon-market-exceeds-expectations/)
720 [carbon-market-exceeds-expectations/](https://www.refinitiv.com/perspectives/future-of-investing-trading/chinas-national-carbon-market-exceeds-expectations/) (2021).
- 721 19. Global Energy Monitor. *Global Coal Plant Tracker, Jun 2023 Release. Jan 2023 release*
722 (2023).
- 723 20. Qin, Y. *et al.* Environmental Consequences of Potential Strategies for China to Prepare for
724 Natural Gas Import Disruptions. *Environ Sci Technol* **56**, 1183–1193 (2022).
- 725 21. Gordon, D. *et al.* Evaluating net life-cycle greenhouse gas emissions intensities from gas
726 and coal at varying methane leakage rates. *Environmental Research Letters* **18**, 084008
727 (2023).

- 728 22. He, G. *et al.* Rapid cost decrease of renewables and storage accelerates the
729 decarbonization of China's power system. *Nat Commun* **11**, 1–9 (2020).
- 730 23. Wang, Y. *et al.* Accelerating the energy transition towards photovoltaic and wind in
731 China. *Nature* **619**, 761–767 (2023).
- 732 24. Global Energy Monitor. Global Wind Power Tracker, May 2023 release. (2023).
- 733 25. Global Energy Monitor. Global Solar Power Tracker, May 2023 release. (2023).
- 734 26. Buonocore, J. J., Salimifard, P., Magavi, Z. & Allen, J. G. Inefficient Building
735 Electrification Will Require Massive Buildout of Renewable Energy and Seasonal Energy
736 Storage. *Sci Rep* **12**, 11931 (2022).
- 737 27. Chen, X. *et al.* Pathway toward carbon-neutral electrical systems in China by mid-century
738 with negative CO₂ abatement costs informed by high-resolution modeling. *Joule* **5**, 2715–
739 2741 (2021).
- 740 28. Frew, B. *et al.* The curtailment paradox in the transition to high solar power systems.
741 *Joule* **5**, 1143–1167 (2021).
- 742 29. Zhuo, Z. *et al.* Cost increase in the electricity supply to achieve carbon neutrality in China.
743 *Nat Commun* **13**, 3172 (2022).
- 744 30. Huang, P. *et al.* A review of data centers as prosumers in district energy systems:
745 Renewable energy integration and waste heat reuse for district heating. *Appl Energy* **258**,
746 114109 (2020).
- 747 31. Yu, M., Li, S., Zhang, X. & Zhao, Y. Techno-economic analysis of air source heat pump
748 combined with latent thermal energy storage applied for space heating in China. *Appl*
749 *Therm Eng* **185**, 116434 (2021).
- 750 32. Sepulveda, N. A., Jenkins, J. D., Edington, A., Mallapragada, D. S. & Lester, R. K. The
751 design space for long-duration energy storage in decarbonized power systems. *Nat Energy*
752 **6**, 506–516 (2021).
- 753 33. Navidi, T., El Gamal, A. & Rajagopal, R. Coordinating distributed energy resources for
754 reliability can significantly reduce future distribution grid upgrades and peak load. *Joule*
755 **7**, 1769–1792 (2023).
- 756 34. Fan, J.-L. *et al.* A net-zero emissions strategy for China's power sector using carbon-
757 capture utilization and storage. *Nat Commun* **14**, 5972 (2023).
- 758 35. Levesque, A., Osorio, S., Herkel, S. & Pahle, M. Rethinking the role of efficiency for the
759 decarbonization of buildings is essential. *Joule* **7**, 1087–1092 (2023).
- 760 36. Gross, R. & Hanna, R. Path dependency in provision of domestic heating. *Nat Energy* **4**,
761 358–364 (2019).
- 762 37. Global Energy Monitor. *Global Steel Plant Tracker, March 2022 (v2) Release.* (2023).
- 763 38. Guo, Y. *et al.* Benefits of infrastructure symbiosis between coal power and wastewater
764 treatment. *Nat Sustain* **5**, 1070–1079 (2022).
- 765 39. The Ministry of Housing and Urban-Rural Development. *Chinese Urban Infrastructure*
766 *Statistical Yearbook 2020.* (2020).
- 767 40. Chen, Y. *et al.* Provincial and gridded population projection for China under shared
768 socioeconomic pathways from 2010 to 2100. *Sci Data* **7**, 83 (2020).
- 769 41. Wang, R. *et al.* A high spatial resolution dataset of China's biomass resource potential. *Sci*
770 *Data* **10**, 384 (2023).
- 771 42. Wang, R. *et al.* Alternative Pathway to Phase Down Coal Power and Achieve Negative
772 Emission in China. *Environ Sci Technol* **56**, 16082–16093 (2022).
- 773 43. IEA. *World Energy Outlook 2019.* (2019) doi:10.6027/9789289329996-1-en.

- 774 44. Chen, J. *et al.* Case study on combined heat and water system for nuclear district heating
775 in Jiaodong Peninsula. *Energy* **218**, 119546 (2021).
- 776 45. Li, Y., Chang, S., Fu, L. & Zhang, S. A technology review on recovering waste heat from
777 the condensers of large turbine units in China. *Renewable and Sustainable Energy*
778 *Reviews* **58**, 287–296 (2016).
- 779 46. Roberti, R., Bartolini, E. & Mingozzi, A. The fixed charge transportation problem: An
780 exact algorithm based on a new integer programming formulation. *Manage Sci* **61**, 1275–
781 1291 (2015).
- 782 47. Fu, L., Li, Y., Wu, Y., Wang, X. & Jiang, Y. Low carbon district heating in China in
783 2025- a district heating mode with low grade waste heat as heat source. *Energy* **230**,
784 120765 (2021).
- 785 48. Myllyvirta, L., Zhang, X. & Dong, L. *China's Climate Transition: Outlook 2022*. (2022).
- 786 49. National Energy Administration. Blue Book on New Power System Development.
787 http://www.nea.gov.cn/2023-01/06/c_1310688702.htm (2023).
- 788 50. Cui, R. Y. *et al.* A plant-by-plant strategy for high-ambition coal power phaseout in
789 China. *Nat Commun* **12**, 1468 (2021).
- 790 51. Jia, K. Is Natural Gas Power Generation Right or Wrong? *China Energy News* 1 (2019).
- 791 52. Yin, S., Xia, J. & Jiang, Y. Characteristics analysis of the heat-to-power ratio from the
792 supply and demand sides of cities in northern China. *Energies (Basel)* **13**, (2020).
- 793 53. Li, J., Wang, Y., Xu, D. & Xie, K. High-resolution analysis of life-cycle carbon emissions
794 from China's coal-fired power industry: A provincial perspective. *International Journal of*
795 *Greenhouse Gas Control* **100**, 103110 (2020).
- 796